



Certificate of constancy of performance
No. 1325-CPR-3874

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product(s)

Openable wooden windows with fire resistance properties
FT/EI 92.48 and IV92 EI 30
according to the Annex

PLACED ON THE MARKET UNDER THE NAME OF:

AS "ARBO Windows"

Kustes dambis 32, Ventspils, LV-3601, Latvia, Reg. No. 50103451301

ADDRESS OF MANUFACTURER:

AS "ARBO Windows" factory, Kustes dambis 32, Ventspils, LV-3601, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 16034:2014
and
EN 14351-1:2006+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 2 December 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by notified factory production control certification body.

(next surveillance – December 2025)

16 December 2024

Mārtiņš Maskavs
Certification Manager



Certificate issued on 1 (one) page with Annex on 1 (one) page



EN ISO/IEC 17065
S1-182

AS Inspecta Latvia
Skanstes iela 54A, Rīga
LV-1013, Latvija

T. +371 67 607 900
F. +371 67 607 901
latvia@kiwa.com

www.kiwa.com

Inspecta Latvia
Trust, Quality & Progress

CERTIFICATE

Annex

Certificate No. 1325-CPR-3874



Manufacturer: AS "ARBO Windows", Kustes dambis 32, Ventspils, LV-3601, Latvia

Product:

1. Openable wooden windows with fire resistance properties FT/EI 92.48

No.	Declared property	FT/EI 92.48
1.	Fire resistance	EW60
2.	Smoke control	S ₂₀₀ , S _a
3.	Disconnecting ability	released
4.	Self-closing	C
5.	Disconnecting ability resistance	release maintained
6.	Self-closing resistance Cyclicality Corrosion resistance	0 pass

The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-6.2021.1 (22.11.2021.)

2. Openable wooden windows with fire resistance properties IV92 EI 30

No.	Declared property	IV92 EI 30
1.	Fire resistance	EW30 EI ₁ 30 EI ₂ 30 E30
2.	Smoke control	S ₂₀₀ , S _a

The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-2.2022.1 (05.05.2022.)

16 December 2024

Mārtiņš Maskavs
Certification Manager



EN ISO/IEC 17065
S1-182

AS Inspecta Latvia
Skanstes iela 54A, Rīga
LV-1013, Latvija

T. +371 67 607 900
F. +371 67 607 901
latvia@kiwa.com

www.kiwa.com

Certificate

kiwa

Certificate of Conformity
No. 3918/2022

Inspecta Latvia has granted this certificate as proof that

**Non-openable wooden window IV92 EI30 Fix with fire resistance,
according to the Annex**

PRODUCED BY THE MANUFACTURER:
AS "ARBO WINDOWS"

Kustes dambis 32, Ventspils, LV-3601, Latvia, Reg. No. 50103451301

ADDRESS OF MANUFACTURER:
AS "ARBO Windows" factory, Kustes dambis 32, Ventspils, LV-3601, Latvia

Resistance to fire classification according to EN 13501-2:2016 („GTC PRD" (Lithuania)
Classification Report No. 59-3.2022.1 (14.07.2022.)).

EN 13501-2:2016

Fire resistance: class EW30-S_a,S₂₀₀ / EI30-S_a,S₂₀₀ / E30-S_a,S₂₀₀

Certificate remains valid as long as the conditions laid down in the above mentioned standard,
related provisions and the manufacturing conditions in the factory or the FPC itself are not
modified significantly.

Certificate issued: 12.12.2025.
Valid until: 30.12.2028.

Mārtiņš Maskavs
Certification Manager



Certificate is issued on 1 (one) page with Annex on 1 (one) page

AS Kiwa Latvia
Skanstes iela 54, Rīga
LV-1013, Latvija

T. +371 67 607 900
latvia@kiwa.com

www.kiwa.com/lv

Annex

Certificate No. 3918/2022

Product: Non-openable wooden window IV92 EI30 Fix with fire resistance

Dimensions

Height	2200 mm
Width	2200 mm
Thickness	92 mm

Glazing

33.2L SC-12S(Ar)-4ESG SC-10S(Ar)-17.3EI30.

Height	2070 mm	1009 mm	1009 mm
Width	1009 mm	1009 mm	1009 mm
Thickness	50 mm	50 mm	50 mm

The changes in the product design must be in the line with the requirements for the field of application according to the Classification report No. 59-3.2022.1 (14.07.2022.) issued by GTC PRD

12.12.2025.


Mārtiņš Maskals
Certification Manager



The seal is circular with the text "Sertificēšanas institūcija" at the top and "Kiwa Latvia" at the bottom. In the center, the word "kiwa" is written in a stylized blue font.

AS Kiwa Latvia
Skanstes iela 54, Rīga
LV-1013, Latvija

T. +371 67 607 900
latvia@kiwa.com

www.kiwa.com/lv